

STATE BANK OF INDIA
RACPC, GROUND FLOOR
ZONAL OFFICE BUILDING
AMBAWADI, AHMEDABAD



87463 SPL. ADH 11/11/11
110294 AUG 21 2021

ZERO ZERO ZERO ZERO THREE ZERO ZERO 15:35

R.0000300/-PB7113

STAMP DUTY GUJARAT



COSMOS CASTLE International School

Managed by Ramdulari Dhansiram Chandravali Charitable Trust

Survey No. 598/1, Right turn to Markarba Cross Road, Next to Vrindavan Farm,
Opp. YMCA, S.G. Road, Ahmedabad -58 Tel:- 8000334520/9327000520

School Code: 110148

email id. info@ccis.edu.in

affiliation no. 30148

SERIAL No. 2021

RITA D. GANDHI

NOTARY

GOVT. OF INDIA

21 AUG 2021

ફાયર સેફ્ટી બાબત માટેનું સ્વપ્રમાણિત સર્ટિફિકેટ

જરાત ફાયર પ્રિવેન્શન એન્ડ લાઈફ સેફ્ટ મેઝસ એક્ટ - ૨૦૧૩ એન રૂલ્સ - ૨૦૧૪ તેમજ સુધારા વિધાયક ૨૦૨૧મા કરવામા આવેલ જોગવાઈઓ અંતર્ગત તથા શહેરી વિકાસ અને શહેરી ગૃહ નિર્માણ વિભાગના નોટફિકેશન નંબર: GH/V/9 OF 2021/AGN-102021-100-L-I, તા. ૨૨/૦૧/૨૦૨૧ મુજબ અમારી સ્કૂલ / કોલેજ કે જે એજ્યુકેશનલ/ઈસ્ટીટ્યુશનલ બિલ્ડીંગ નું નામ કોસમોસ કેસલ ઇન્ટરનેશનલ સ્કૂલ, સરનામુ સર્વે નં 598/1 મોહમમદ પુરા કોસ રોડ વાચ અમે સી કલ્બ ની સામે એસ જી રોડ અમદાવાદ -380058. સ્થાપના વર્ષ: 1999 અને ની વાસ્તવિક ઉંચાઈ 7.9 મીટર છે. જેથી ઉંચાઈ ગ્રાઉન્ડ ફ્લોરથી બિલ્ડીંગના ધાબા સુધી 8.7 મીટર છે. જેનું બાધકામ ગ્રાઉન્ડ ફ્લોર/ હોલોહોલોપ્લિન્થ / 1 માળ છે. જેનું ફાયર સેફ્ટી સર્ટિફિકેટ પ્રથમ વખત ફાયર એન્ડ ઈમરજન્સી સિવસીઝ દ્વારા મેળવવા મા આ વેલ છે અને નેશનલ બિલ્ડીંગ કોડ ઓફ ઇન્ડિયા પાર્ટ -4 ની ગાઇડલાઇન તેમજ ગુજરાત ફાયર પ્રિવેન્શન લાઈફ સેટી મેજર્સ એક્ટ તથા 2021 માં રજૂ કરવામાં આવેલ સુધારા વિધાયક ની જોગવાઈઓ મુજબ અમારી ઉપરોક્ત સ્કૂલ બિલ્ડીંગ માં આ સાથે જણાવેલ સાધનો ફીટ કરવામાં આવેલ છે. જેનું આ સ્વ પ્રમાણિત સર્ટિફિકેટ છે.

Have portable fire extinguishers (as per IS:15683) been provided? Yes: () No: ()							
Type of F.E	Capacity & Quantity						Total
CO2 (kg)	2 (1)	3 (-)	4.5 (3)	6.5 (-)	9 (-)	22.5 (-)	04
stored presser ABC (kg)	1 (-)	2 (-)	5 (8)	6 (1)	9 (-)	25 (-)	09
Water CO2 (ltr)	9 (-)	(-)	(-)	(-)	(-)	(-)	---
Clean Agent (kg)	2 (-)	4 (-)	5 (-)	10 (-)	(-)	(-)	---
Auto Modular (kg)	2 (-)	5 (-)	10 (-)	15 (-)	(-)	(-)	---


Alarm with Manual Call Point, Sounder & Flasher	No					
Photo luminescent Auto Glow Signages	Firefighting Equipment (No)	Emergency Route Mark (Yes)	Way to Staircase (Yes)	Electrical Hazards (Yes)		
One(1)Hose Reel Hose(25mm) for 1000Sq. Mtr area at Each Floor Level as per Notification	No's- No		Firefighting Pump(450lpm) Capacity (No)	10,000 ltr Water Tank (Yes)		


तारीख: 21-08-2021

सही For, Cosmos Castle International School
नाम :
सिद्धो Jani Dinkar J...
Authorized Signatory/Trustee



BEFORE ME
[Signature]
RITA D. GANDHI
NOTARY
GOVT. OF INDIA
21 AUG 2021





AHMEDABAD MUNICIPAL CORPORATION
AHMEDABAD FIRE AND EMERGENCY SERVICES DEPARTMENT
Danapith Fire Station (Hqrs.) Nr. AM Corporation, Danapith Ahmedabad-380001.
Phone No: 079 22148466/67/68 Fax No:079 22148598

F.B.No. _____, School NOC

25th January 2021

TO WHOM SO EVER IT MAY CONCERN

This is to certify that the management of "Cosmos Castle International School," located at; Survey No. 598/1, right turn to makarba Cross Road, Opp. YMCA, S. G. Road, Ahmedabda. Have provided for the required fire Protection of the School Building and was inspected today and fire risks observed were of very low category and evacuation in case of emergency cannot be a problem.


The Fire Service has **NO OBJECTION** to the above school as it is protected by fire fighting appliances.


- 6 Kg. Capacity ABC type Fire Extinguishers. (01 Nos.)
- 5 Kg. capacity ABC type Fire Extinguishers. (08 Nos.)
- 4.5 Kg. Capacity Co2 type Fire Extinguishers. (03 Nos.)
- 2 Kg. Capacity Co2 type Fire Extinguishers. (01 Nos.)
- All Electrical Supply have ELCB installed at main Junction.


All the Fire equipments installed shall be maintained in working order throughout the validity period of this certificate.

The Certificate is valid till 31st January 2022.

Inspected by:


(M.P. Mistry)
Dy. CFO





Chief Fire Officer
Ahmedabad Municipal Corporation

