

**Copy of the certificate regarding Water, Health & Sanitation issued by  
Medical Officer, Sanand**

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

DATE 4/3/2025

It is to certified that an inspection team headed by Dr. S. K. Kapadia, Medical Officer from Primary Health Center- Shela Ta- Sanand , Dist. Ahmedabad , Inspected the COSMOS CASTLE INTERNATIONAL, SCHOOL, GREEN CAMPUS Situated at Survey No. 684, Godhavi, Ahemdabad on 18/02/2025 and on the basis of Water Test Report (Attached) bearing no: Outward/Micro/GMERS/No.197/25 dated 22/02/2025 of Department of Microbiology, GMERS Medical College & General Hospital, Sola ,Ahmedabad ; has safe drinking water facilities for the students and members of staff of the institution. School has also maintained the hygienic sanitation condition in the school building & in the campus as per norms prescribed by the Central/ state/ U.T. Govt. This certificate is valid till 21/02/2026



Signature with seal: .....

*[Signature]* 4/3/25  
Dr. S. K. Kapadia  
Medical Officer  
PHC-SHELA  
Ta. Sanand  
14 MAR 2025

To,  
The Principal,  
Cosmos Castle International School, Green Campus  
Survey No. 684, Godhavi ,Ahmedabad-382115

*[Signature]*  
Principal,  
Cosmos Castle International School Green Campus  
Ahmedabad

*[Signature]*  
Managing Trustee,  
Cosmos Castle International School Green Campus  
Ahmedabad

# Copy of the Water Examination Report



**Gujarat**  
Testlab Private Limited



TC-5961

F-16,17, Madhavpura Market,  
Shahibaug, Ahmedabad-380004  
Ph. : 079-25626040, 25624821  
M : 7486086091, 9601389681  
E : gujlab@gmail.com/gujlab.info@gmail.com  
Web : www.gujaratlaboratory.com

## TEST REPORT

Doc. No : GTL/D/7.5/02


ULR-TC596125300000286F


Page 1 of 2

<b>Report Issued To :</b> Cosmos Castle International School <b>Green Campus</b> Managed by : Ramdulari Dhansiram Agrasen Charitable Trust Survey No : 684, Godhavi, Bopal,, Ahmedabad, Gujarat <b>Phone No :</b> 9327000520 <b>Email :</b> suresh241@gmail.com	<b>Test Report No</b> : GTL/01250127002 <b>Date of Receipt</b> : 27/01/2025 <b>Date of Issue</b> : 30/01/2025 <b>Customer's Ref. No</b> : N.M
--	--

<b>Sample Described as</b> : Drinking Water <b>Sample Qty</b> : 2.0 Ltr <b>Packing Mode</b> : Sample Packed in Plastic Bottle  <b>Sample Condition</b> : Satisfactory <b>Marking</b> : N.M  <b>Sample Drawn By</b> : Customer <b>Date of Starting of Test</b> : 27/01/2025	<b>Mfg. Date</b> : N.M. <b>Exp. Date</b> : N.M. <b>B.No</b> : N.M  <b>Date of Completion</b> : 30/01/2025
--	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
<b>Chemical Water</b>						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.96	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	110	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	3.33	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	43.79	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	1.95	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as CGH5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	14.56	1	IS:3025(P-21)
<b>Biological Water</b>						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	--	IS 15185 : 2016

  
 Principal,  
 Cosmos Castle International School Green Campus  
 Ahmedabad

  
 Managing Trustee,  
 Cosmos Castle International School Green Campus  
 Ahmedabad

# Gujarat

## Testlab Private Limited



F-16,17, Madhavpura Market,  
Shahibaug, Ahmedabad-380004  
Ph. : 079-25626040, 25624821  
M : 7486086091, 9601389681  
E : gujlab@gmail.com/gujlab.info@gmail.com  
Web : www.gujaratlaboratory.com

Test Report No : GTL/01250127002

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit In the Absence of Alternate Source	Result	Quant. Limit	Test Method
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	—	IS 15185 : 2016

Opinion : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification



For NABL Scope

*Mamta Bhavsar*  
Mamta Bhavsar  
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

*Hemal Darji-Krishna Amin*  
Hemal Darji-Krishna Amin  
Autho. Signatory

\*\*\* END OF REPORT \*\*\*

*Principal*  
Principal,  
Cosmos Castle International School Green Campus  
Ahmedabad

*Managing Trustee*  
Managing Trustee,  
Cosmos Castle International School Green Campus  
Ahmedabad