

**Copy of the Certificate regarding Water, Health & Sanitation issued by  
Dy. Health Officer, Ahmedabad Municipal Corporation**

PPS.N - B  
27/12/25

INCHARGE NO. 38  
18/12/25

Ahmedabad Municipal Corporation  
HEALTH DEPARTMENT

No. 237  
Date: 27/12/25

**Sanitary Convenience Certificate**

A Certificate for Sanitary Convenience is used to the Manager / Secretary / Organiser  
of the Talkies / School / Theatre named Cosmos castle International  
School - Sureshbhai Agrawal Situated  
at S.No. 598/2, Makerba cross Rd., S.G. Highway for  
the period of 12 months / Days i.e. from 1/1 2025 to 31/12 2025


"Issued Subject to NOC from other Concerned Departments"

Copy to :-  
1. The manager/Secretary/Trustee (AMC)  
2. The Commissioner of Police, Ahmedabad.

Sanitary Superintendent  
South Western Zone (AMC)

Dy. Director (SWM)  
Dy. Health Officer (AMC)  
Ahmedabad Municipal Corporation  
Zone : \_\_\_\_\_

  
Principal  
Cosmos Castle International School

For, Cosmos Castle International School  
  
Authorised Signatory/Trustee

# Copy of the Water Examination Report



**Gujarat**  
Testlab Private Limited



TC-5961

F-18,17, Madhavpura Market,  
Shahibaug, Ahmedabad-380004  
Ph. : 079-25626040, 25624821  
M : 7486086091, 9601389681  
E : gujlab@gmail.com/gujlab.info@gmail.com  
Web : www.gujaratlaboratory.com

## TEST REPORT

Doc. No : GTL/D/7.5/02

Page 1 of 2


ULR-TCS9612530000285F


<b>Report Issued To :</b> Cosmos Castle International School Survey No:598/1, Mumatpura Cross Road, Right Trun to Makarba Cross Road, Next to Vrindavan Farm, S.G.Highway,, Ahmedabad, Gujarat <b>Phone No :</b> 9327000520 <b>Email :</b> info@ccis.edu.in	<b>Test Report No</b> : GTL/01250127001 <b>Date of Receipt</b> : 27/01/2025 <b>Date of Issue</b> : 30/01/2025 <b>Customer's Ref. No</b> : N.M
---	--

<b>Sample Described as</b> : Drinking Water <b>Sample Qty</b> : 2.0 Ltr <b>Packing Mode</b> : Sample Packed in Plastic Bottle <b>Sample Condition</b> : Satisfactory <b>Marking</b> : N.M <b>Sample Drawn By</b> : Customer <b>Date of Starting of Test</b> : 27/01/2025	<b>Htg. Date</b> : N.M. <b>Exp. Date</b> : N.M. <b>B.No</b> : N.M <b>Date of Completion</b> : 30/01/2025
--	---

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
<b>Chemical Water</b>						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Occur	Agreeable	Agreeable	Agreeable	—	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	6.69	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	112	5	IS:3025(P-16)
7	Caloum (as Ca), mg/l	Max.75	Max.200	1.67	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	39.77	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	0.49	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	4.16	1	IS:3025(P-21)
<b>Biological Water</b>						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	—	IS 15185 : 2016

Note : General Terms & Conditions as mentioned overleaf

  
 Principal  
 Cosmos Castle International School

For, Cosmos Castle International School  
  
 Authorised Signatory/Trustee

Test Report No : GTL/01250127001

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit In the Absence of Alternate Source	Result	Quant. Limit	Test Method
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	—	IS 15185 : 2016

**Opinion :** Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification



*Mamta Bhavsar*  
Reviewed By



\*\*\* END OF REPORT \*\*\*

FOR, GUJARAT TESTLAB PVT. LTD

*Hemal Darji-Krishna Amin*  
Hemal Darji-Krishna Amin

Autho. Signatory

Note : General Terms & Conditions as mentioned overleaf

*Principal*  
Principal  
Cosmos Castle International School

For, Cosmos Castle International School

*Authorized Signatory/Trustee*  
Authorized Signatory/Trustee